

WORCESTER COUNTY
Snow Hill Health Dept. Parking Lot Resurfacing BID

ADDENDUM #1

DATED: 8/30/2022

Page 1 of 1

REFERENCE: 1. Drainage Issue Correction

➤ **Please include the correction of drainage issues in your contract price.**

A drainage issue exists in the area of the driveway where parking areas meet and indicated by asphalt patches and deterioration. This area accumulates water and does not drain properly to the storm water management pond on the southeastern area of the property. Your bid should include regrading all areas to provide proper drainage of parking areas and driveway.

Please contact Michael Hutchinson, 410-632-3766 with questions regarding this addendum.

End of Addendum

mnh 8/30/2022