



Worcester County Administration Office  
1 West Market Street, Room 1103  
Snow Hill, MD 21863  
Ph. 410-632-1194 Fax 410-632-3131  
Email: [nrice@co.worcester.md.us](mailto:nrice@co.worcester.md.us)

---

## **Addendum # 1 Pocomoke Middle School Basketball Court Renovation**

Date of Addendum: 11/2/2023

### **NOTICE TO ALL BIDDERS AND PLANHOLDERS**

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

### **BID SUBMITTAL DEADLINE**

The bid submittal time has not been changed.

### **1.0 – ATTACHMENTS**

<b>Item</b>	<b>Description</b>
1.1	Please see the attached Basketball Court Dimensions

### **2.0 – QUESTIONS AND ANSWERS**

The following questions and answers are provided as a matter of information to clarify issues raised about the Bid Documents.

<b>Item</b>	<b>Questions and Answers</b>
2.1	Q. Please provide Milling Specs, what are the depth requirements (if required)? A. <b>County staff has reviewed, and no milling will be needed.</b>
2.2	Q. The Manufacturer requires 2 coats of Re Surfacer but on the bid it states only one coat to be used. A. <b>2 coats of resurfacer is to be used according to manufactures guidelines.</b>
2.3	Q. Please provide the Basketball Court Design Plans A. <b>Please see attached.</b>

**END OF ADDENDUM**

