



Worcester County Administration Office  
1 West Market Street, Room 1103  
Snow Hill, MD 21863  
Ph. 410-632-1194 Fax 410-632-3131  
Email: [nrice@co.worcester.md.us](mailto:nrice@co.worcester.md.us)

## **Addendum # 2 Pocomoke Middle School Basketball Court Renovation**

Date of Addendum: 11/8/2023

### **NOTICE TO ALL BIDDERS AND PLANHOLDERS**

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

### **BID SUBMITTAL DEADLINE**

The bid submittal time has not been changed.

### **1.0 – QUESTIONS AND ANSWERS**

The following questions and answers are provided as a matter of information to clarify issues raised about the Bid Documents.

<b>Item</b>	<b>Questions and Answers</b>
1.1	Q. Under Section IV; Bid Specifications; D.5 – Confirm that only the holes from the sports equipment is to have base asphalt installed level with the existing surface. Would the use of 9.5mm surface be acceptable in lieu of 19mm base for this backfill operation? A. <b>Correct and 9.5mm would be ok to use in this case since no heavy traffic or cars will be driving on it.</b>
1.2	Q. The existing paved area is not square. Is the intent to pave back the existing footprint? A. <b>Yes</b>
1.3	Q. Under Section IV; Bid Specifications; F.1 – It asks for (2) posts and goals; however, it appears that there are two courts being done. Should this quantity be changed to four (4)? A. <b>No, there are only 2 goals going back for a single basketball court. Another Basketball/soccer system will be installed by another vendor in the area where the other existing court is. However, the entire footprint is to be resurfaced.</b>
1.4	Q. Can access to the work be from the double gate at Moore Street? A. <b>Yes</b>
1.5	Q. What is the warranty period? A. <b>Please see Section III, Subsection Q of the Bid Documents.</b>

**END OF ADDENDUM**