



Worcester County Administration Office  
1 West Market Street, Room 1103  
Snow Hill, MD 21863  
Ph. 410-632-1194 Fax 410-632-3131  
Email: [purchasing@co.worcester.md.us](mailto:purchasing@co.worcester.md.us)

## **Overhead Pipe Corrosion Protection - Ocean Pines WWTP Addendum # 1 February 5, 2026**

### **NOTICE TO ALL BIDDERS AND PLANHOLDERS**

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

### **BID SUBMITTAL DEADLINE**

The bid submittal time has not been changed.

### **1.0 – ATTACHMENTS**

Item	Description
1	Site Plan
1	Pre-bid attendee list

### **2.0 – CLARIFICATIONS**

The following clarifications are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Description
1	Site plan attached.
2	Under section IV: Bid Specs, K.2.c: The finish will be two (2) coats of a UV resistant polyurethane coating.
3	No bid bond is required for this project.
4	Pipe labels will be done with a five (5) inch tall stencil of a contrasting color to the pipe coating using a UV resistant polyurethane coating.
5	Pipe color shall be a brown or green color that will be decided during the construction submittal process.

### **3.0 – QUESTIONS AND ANSWERS**

The following questions and answers are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Questions and Answers

**END OF ADDENDUM**