



Worcester County Administration Office
 1 West Market Street, Room 1103
 Snow Hill, MD 21863
 Ph. 410-632-1194 Fax 410-632-3131
 Email: purchasing@co.worcester.md.us

Addendum # 1 – Glen Riddle Water Tank Rehabilitation (clarification on coatings)

January 27, 2026

Date of Addendum:

NOTICE TO ALL BIDDERS AND PLANHOLDERS

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

BID SUBMITTAL DEADLINE

The bid submittal time has not been changed.

1.0 – ATTACHMENTS

Item	Description

2.0 – CLARIFICATIONS

The following clarifications are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Description
1	<p>MATERIALS</p> <p>A. The coating system specified herein is based on products manufactured by Tnemec Company, Inc. For basis of bid Contractor shall furnish coatings manufactured by Tnemec, or equivalent Sherwin Williams coating system.</p> <p>B. All coatings shall be from the same manufacturer.</p> <p>C. Manufacturers wishing to be considered as an acceptable alternate shall not be substituted during the bidding period. After contract award, the Contractor may submit a request for substitution for an alternate coating manufacturer. The Owner and Engineer will review the substitution request after award. If the proposed manufacturer is not approved, the Contractor shall provide a coating system from one of the specified basis-of-design manufacturers at no additional cost to the Owner. Requests for substitution shall include the below information at minimum.</p> <p>a. Coating system data sheets</p> <p>b. NSF/ANSI 61 certification for potable water coatings (where applicable).</p>

	<p>c. A minimum of 5 completed elevated water storage tank projects of similar size and scope within the last 10 years</p> <p>d. Project references with Owner contact information.</p> <p>e. Written certification that the proposed coating system meets or exceeds the specified system performance requirements.</p>
--	--

3.0 – QUESTIONS AND ANSWERS

The following questions and answers are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Questions and Answers

END OF ADDENDUM