



Worcester County Administration Office
 1 West Market Street, Room 1103
 Snow Hill, MD 21863
 Ph. 410-632-1194 Fax 410-632-3131
 Email: purchasing@co.worcester.md.us

Addendum # 1 - Central Landfill Cell 1 Pump Station Upgrades (Questions & Answers)

04/16/26

Date of Addendum:

NOTICE TO ALL BIDDERS AND PLANHOLDERS	
The Proposal Documents for the above-referenced Project are modified as set forth in this Addendum. The original Proposal Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Proposal Documents. Vendors will take this Addendum into consideration when preparing and submitting a Proposal and shall acknowledge receipt of this Addendum in the space provided in the Proposal Documents.	
PROPOSAL SUBMITTAL DEADLINE	
The Proposal submittal time has not been changed.	
1.0 – ATTACHMENTS	
Item	Description
2.0 – CLARIFICATIONS	
The following clarifications are provided as a matter of information to clarify issues raised about the Proposal Documents.	
Item	Description
3.0 – QUESTIONS AND ANSWERS	
The following questions and answers are provided as a matter of information to clarify issues raised about the Proposal Documents.	
Item	Questions and Answers
	Do we provide one spare pump per station? Per Specification Section 01 11 00 – 2, Item 1.2.C.10, Provide (1) additional spare 2hp Hydromatic Submersible grinder pump.
	What size hatches go on the valve vaults? The plans show two different sizes. Provide 36”x36” hatches for all valve vaults.
	Is the Omnisite Crystal Ball remote monitoring panel part of the items being provided by the county? See Section F of Specification Manual, Page 2, last Header entitled “Telephone Dialer – Cellular”.

END OF ADDENDUM