



Worcester County Administration Office
1 West Market Street, Room 1103
Snow Hill, MD 21863
Ph. 410-632-1194 Fax 410-632-3131
Email: purchasing@co.worcester.md.us

Addendum # 5 – Water Supply Capacity Management Plan (Deadline Change & Q&As #3)

04/21/26

Date of Addendum:

NOTICE TO ALL BIDDERS AND PLANHOLDERS

The Proposal Documents for the above-referenced Project are modified as set forth in this Addendum. The original Proposal Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Proposal Documents. Vendors will take this Addendum into consideration when preparing and submitting a Proposal and shall acknowledge receipt of this Addendum in the space provided in the Proposal Documents.

PROPOSAL SUBMITTAL DEADLINE

The Proposal submittal time has been changed to 04/30/26 at 2 p.m.

1.0 – ATTACHMENTS

Item	Description

2.0 – CLARIFICATIONS

The following clarifications are provided as a matter of information to clarify issues raised about the Proposal Documents.

Item	Description

3.0 – QUESTIONS AND ANSWERS

The following questions and answers are provided as a matter of information to clarify issues raised about the Proposal Documents.

Item	Questions and Answers

	<ol style="list-style-type: none"><li data-bbox="337 191 1360 359">1. Other than GIS, what water system records are available for review of the existing systems (as-built, record mapping, design drawings, proposed projects, etc.)? To the extent that record drawings from both infrastructure and development projects are available, they can be provided to the selected Consultant upon request.<li data-bbox="337 394 1409 527">2. What system information is currently available in the GIS mapping (diameter, material, install date, meter locations, FH id numbers, etc.)? What is the percent complete? Piping (diameter, material, install date, fire hydrants) is approximately 95% complete, meter locations are approximately 75% complete.<li data-bbox="337 562 1409 961">3. Can the County provide parameters for the emergency/outage scenario analysis for the water model? Does the County have an assumed number of emergency scenarios to be evaluated? The County has not explicitly defined a fixed number of emergency or outage scenarios within Task 3, nor has it established a prescribed minimum quantity for evaluation. However, Section (h), “Emergency/outage scenario analysis,” is understood to require the Consultant to develop and evaluate a set of representative and critical system failure conditions that test system resiliency under both localized and system-wide stress conditions. These scenarios are expected to reflect industry-standard water distribution modeling practice and be sufficient to assess system redundancy, fire protection capability, and operational reliability under current and 10-year growth conditions.<li data-bbox="337 997 1377 1094">4. Section III, paragraph O includes requirements for performance and payment bonds. Will these bonds be required for this professional services contract? These bonds are not required for this professional services contract.
--	--

END OF ADDENDUM