



Worcester County Administration Office  
 1 West Market Street, Room 1103  
 Snow Hill, MD 21863  
 Ph. 410-632-1194 Fax 410-632-3131  
 Email: [purchasing@co.worcester.md.us](mailto:purchasing@co.worcester.md.us)

**Addendum # 2 – Riddle Farm Overhead Door Replacement**  
**(attachments, clarifications & deadline)**

Date of Addendum: May 26, 2026

<b>NOTICE TO ALL BIDDERS AND PLANHOLDERS</b>	
The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.	

<b>BID SUBMITTAL DEADLINE</b>	
The bid submittal time has changed to <b>06/04/26 at 2 p.m.</b>	

<b>1.0 – ATTACHMENTS</b>	
<b>Item</b>	<b>Description</b>
1	Attached are the basis of design for the proposed overhead doors and opener.

<b>2.0 – CLARIFICATIONS</b>	
The following clarifications are provided as a matter of information to clarify issues raised about the Bid Documents.	
<b>Item</b>	<b>Description</b>
1	The base of design for the proposed overhead doors will be the Cornell ESD20CR (Insulated) Rolling Door with 316 Stainless Steel materials. The base design door operator will be the Model SHN79-500, 1/2hp, 115v operator. If bidding an alternative product please provide the specification for the alternate with the bid submission.
2	The door installed at the Mystic Harbour Water Treatment Plant will require the replacement of the wood jams and packing out of the door to allow installation on the inside of the door frame without removal of the existing electrical conduits.

<b>3.0 – QUESTIONS AND ANSWERS</b>	
The following questions and answers are provided as a matter of information to clarify issues raised about the Bid Documents.	
<b>Item</b>	<b>Questions and Answers</b>

**END OF ADDENDUM**