

18 June 2020  
EA Project No. 6282601.0005

**TO:** Bidders of Record

**FROM:** EA Engineering, Science, and Technology  
11200 Racetrack Road, Unit 101A  
Ocean Pines, MD 21811

**RE:** Addendum No. 2  
Worcester County Department of Public Works  
Ocean Pines Pump Station “S and P” Upgrades  
June 2020

**TO ALL BIDDERS:** This Addendum No. 2 contains modifications to the Contract Documents. This Addendum No. 2 shall supplement, amend, and become part of the Contract Documents and Construction Specifications for the title project and contract.

Except as may be otherwise described, bidding requirements, materials, and workmanship for the work described herein shall conform to all requirements of the original Contract Documents, except as modified using succeeding addenda. The following Addendum to the specifications and drawings is made a part of the project and takes precedence over the section of the specifications, in part, and/or drawings, as originally written, or as modified in succeeding addenda. All bids shall be based on this addendum in accordance with the Bidding Documents.

- Modifications to Contract Documents
  - Contract Documents and Specifications
- Response to Comments

## **MODIFICATIONS TO CONTRACT DOCUMENTS**

### Construction Specifications:

1. Section 01 11 00 SUMMARY OF WORK, Section 1.2 Scope, Part E, DELETE, “The “CONTRACTOR shall be responsible for mounting and properly grounding the directional antenna at Pump Stations “S” and “P”. CONTRACTOR shall be responsible for programming the programmable controller and operator interface display located at both pump stations.” and SUBSTITUTE, “The CONTRACTOR shall be responsible for mounting and properly grounding the directional antenna at Pump Stations “S” and “P”.”
2. Section 01 11 00 SUMMARY OF WORK, Section 1.2 Scope, Part F, DELETE.

## **RESPONSE TO COMMENTS – REVISIONS**

The following questions were presented in writing.

Question M: Who is to furnish the Scada Radio, Floats, Level Transducer, Radio Antenna, Softstart?

**Response M:** Addendum No. 1 Response:

*Control panel will be prepurchased by Worcester County. None of these items are required by the bid documents.*

Addendum No. 2 Clarification:

*The intent of the response was to clarify the County will provide the Control Panel and pump control components within the control panel. The spread spectrum radio and soft starts will be provided and installed by the County. However, the level sensors, float switches and directional antenna are required to be supplied and installed by the Contractor.*

Question P: Who is providing the programming to the Scada?

**Response P:** Addendum No. 1 Response:

*Worcester County*

Addendum No. 2 Clarification:

*Worcester County will provide the programming associated with the SCADA to include the programming for the programmable controller, operator interface display and updating the Trihedral software on the PC computers located at the Ocean Pines WWTP.*