

## IMPORTANT NOTICE

Consumer Confidence Report

### EDGEWATER ACRES/ NANTUCKET POINT SERVICE AREA 2015 ANNUAL DRINKING WATER QUALITY REPORT PWSID # 023-0020

#### INTRODUCTION

The Water & Wastewater Division of the Worcester County Department of Public Works is responsible for the provision of the safest possible drinking water to its customers in the Nantucket Point Service Area. During the period from January 1 to December 31, 2014, we conducted tests for drinking water contaminants and tested at least once every month for Total Coliform and Fecal Coliform Bacteria as required by Federal and State law. We detected several contaminants and all were found to be significantly below established standards.

This brochure is a snapshot of the quality of the water that was provided to you in 2014. Included are details about the source of your water, what your water contains, and how your water compares with the standards established by the Environmental Protection Agency (EPA) and the Maryland Department of the Environment (MDE). If you have any questions about this report or need additional information concerning the drinking water being supplied to you, please call Gary Serman at 410-641-5251, extension 115, between 7:30 a.m. and 4:00 p.m. any weekday.

#### OUR WATER IS SAFE, HOWEVER

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer who are undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risks of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

#### SOURCE OF WATER

We purchased water from Artesian Water Company of Delaware in 2013 and we were supplied by both their South Bethany and Bayville water plants.

#### INFORMATION

While we do not have regularly scheduled meetings with your community, our personnel are available to answer any questions that you may have or to provide information concerning the operation of the water treatment system. To contact us, you can call Gary Serman at 410-641-5251, extension 115, or you can write to us at 1000 Shore Lane, Berlin, Maryland 21811.

#### LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Worcester County is responsible for providing high quality drinking water, but cannot control the variety of

materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.”

#### GENERAL

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in the water before we treat it include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wild life.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture and residential uses.
- *Radioactive contaminants*, which are naturally-occurring.
- *Organic chemical contaminants*, including synthetic and volatile chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic tanks.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

## EDGEWATER ACRES/ NANTUCKET POINT SERVICE AREA WATER QUALITY DATA

The table below lists all the drinking water contaminants that we detected during the 2014 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1-December 31, 2014. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Terms & abbreviations used below:

- **Maximum Contaminant Level Goal (MCLG):** the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL):** the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Action Level (AL):** the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **ppb:** parts per billion or micrograms per liter • **ppm:** parts per million or milligrams per liter • **ppt:** parts per trillion, **pCi/l:** picocuries per liter (a measure of radiation)

	Violation? Yes(Y) No(N)	Unit of Measure	Highest Level Allowed (MCL)	Ideal Goal (MCLG)	Highest Level Detected	Annual Range	Major Sources
<b>Inorganic Contaminants</b>							
Barium	N	ppm	2	2	0.0292	0.0135 – 0.0292	Erosion of natural deposits.
Nitrate	N	ppm	10	10	0.093	Nd-0.093	Runoff from fertilizer use, leaching from septic tanks, sewage, or erosion of natural deposits
Fluoride	N	ppm	2	2	1.22	0.09 – 1.22	Erosion of natural deposits. Water additive that promotes strong teeth.
Chromium	N	ppb	100	100	0.2	Nd-0.2	Erosion of natural deposits
<b>Synthetic Organic Contaminants including pesticides and herbicides</b>							
Dalapon	N	ppb	200	200	0.344	0.28 -0.344	Runoff from herbicide used on row crops.
Di(2-ethylhexyl)adipate	N	ppb	400	400	0.081	nd – 0.081	Discharge from industrial chemical factories.
Di(2-ethylhexyl)phthalate	N	ppb	6	0	2.48	nd-2.48	Discharge from rubber and industrial chemical factories.
Hexachlorocyclopentad	N	ppb	50	50	0.037	Nd -0.037	Discharge from chemical factories.
<b>Radiological Contaminants</b>							
Gross Alpha Emitters	N	pCi/l	15	0	0.45	0.37 -0.45	Erosion of natural deposits
<b>Disinfection/ Disinfection by-Products</b>							
Chlorine (free and total)	N	ppm	4 (MRDL)	4 (MRDLG)	2.64	Nd - 2.64	Disinfectant used in drinking water industry.
Haloacetic Acids, total (Maryland)	N	ppb	60	0	38.8	18.85 – 38.8	By-product of drinking water chlorination
Haloacetic Acids, total <sup>4</sup> (Delaware)	N	ppb	60	0	30.15	9.40 -47.3	By-product of drinking water chlorination.
Dibromoacetic Acid	N	ppb	n/r		1.42	nd-1.42	By-product of drinking water chlorination
Dichloroacetic Acid	N	ppb	n/r		16.90	nd-16.90	By-product of drinking water chlorination
Trichloroacetic Acid	N	ppb	n/r		29.10	9.40 -29.10	By-product of drinking water chlorination
Trihalomethanes, total (Maryland)	N	ppb	80	0	70.79	37.92 -70.79	By-product of drinking water chlorination.
Trihalomethanes, total <sup>4</sup> (Delaware)	N	ppb	80	0	59.03	25.70 – 76.90	By-product of drinking water chlorination.
Bromodichloromethane	N	ppb			22.20	8.44 -22.20	By-product of drinking water chlorination
Chloroform	N	ppb			47.7	14.50 – 47.70	By-product of drinking water chlorination
Dibromochloromethane	N	ppb			7.22	2.60 -7.22	By-product of drinking water chlorination
<b>Unregulated Contaminants</b>							
Alkalinity, total	N	ppm	n/r		128	76 - 128	
Carbon dioxide, free	N	ppm	n/r		15.31	4.09 – 15.31	
Chlorate	N	ppb	n/r		73	Nd-73	
Chromium, Hexavalent	N	ppb	n/r		0.13	0.07 – 0.13	
Conductivity	N	umhos	n/r		364	288 -364	
Di-N-Butylphthalate	N	ppb	n/r		0.559	Nd- 0.559	

Hardness, calcium	N	ppm	n/r		90	45 – 90	
Hardness, total	N	ppm	n/r		108	79 - 108	
Phosphate, total	N	ppm	n/r		0.59	Nd – 0.59	
Sodium	N	ppm	n/r		51.2	Nd – 51.2	
Strontium	N	ppb	n/r		130	110-130	
Turbidity	N	NTU	5	1	0.247	0.199- 0.247	Soil runoff.
<b>Lead &amp; Copper<sup>3</sup> (Maryland)</b>							
90th Percentile Lead (2012 Data)	N	ppm	15	0	0.004		Corrosion of household plumbing systems.
90th Percentile Copper (2012 Data)	N	ppm	1.3	1.3	0.227		Corrosion of household plumbing systems.
<b>Microbiological Contaminants</b>		<b>Highest level allowed</b>	<b>Highest level detected</b>				
<b>Total Coliform</b>		N					
Highest number of total coliform positive samples in any one month		No more than 5% per month	One sample per month was collected by Worcester County personnel on the Maryland portion of the water distribution system and all samples were negative.			Naturally present in the environment.	
<b>Secondary Contaminants</b>	<b>violation</b>	<b>Unit of measure</b>	<b>SMCL</b>	<b>MCLG</b>	<b>Ave. Level Detected</b>	<b>Range Of level detected</b>	
Chloride	N	ppm	250		15.51	11.8 – 32.5	
Iron	N	ppm	0.3		0.655	0.09-1.22	
Manganese	N	ppm	0.05		0.005	0.005-0.006	
pH, field	N	0-14 scale	6.5- 8.5		7.35	6.70- 8.67	
Solids, total dissolved	N	ppm	500		240	215-265	