



Worcester County Administration Office
1 West Market Street, Room 1103
Snow Hill, MD 21863
Ph. 410-632-1194 Fax 410-632-3131
Email: nrice@co.worcester.md.us

Addendum # 1 Berlin Health Department Roof Coating

Date of Addendum: 3/8/24

NOTICE TO ALL BIDDERS AND PLANHOLDERS

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid, and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

BID SUBMITTAL DEADLINE

The bid submittal time has been changed from 2:30pm on Thursday, March 14, 2024 to Thursday, March 21, 2024 at 2:30pm.

1.0 – QUESTIONS AND ANSWERS

The following questions and answers are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Questions and Answers
1.1	<p>Q. Please confirm an Acrylic roof coating system which meets or exceeds Uniflex is acceptable.</p> <p>A. The County is only using Uniflex system so our local rep is involved with inspection and warranty process/procedure</p>
1.2	<p>Q. In the Paint Specifications- Bond Plex is listed as the finish coat, an advantage of Bond Plex and as per there Data Sheet is no primer is required. In the Paint Specifications Procryl is listed to be applied for the primer. Please confirm Procryl is to be applied. I have attached the PDS for Bond Plex for ease of reference.</p> <p>A. Procryl is a rust inhibitive primer used where required. This was an option to the Uniflex KSTO36520 rust inhibitive primer also listed</p>

END OF ADDENDUM